



ನಗರಸಭಾ ಕಾರ್ಯಾಲಯ
ಚಾಮರಾಜನಗರ

Office : 08226-222035
Fax : 08226-222566
Commissioner : 08226-222566
Help Line : 08226-224239
Email : itstaff_ulb_chamarajanagar@yahoo.co.in
Website: www.chamarajanagaracity.gov.in

ಸಂಖ್ಯೆ: ನ.ಸ.ಚಾ./ಆ.ಶಾ/ಸ್ಯಾ.ಪ್ರ.ಪ/ಪಿಆರ್./02/2025-26


ದಿನಾಂಕ:11-03-2026

SANITARY CERTIFICATE

I hereby declare that the building and premises of JSS PUBLIC SCHOOL, B.Rachaiiah Double Road, Chamaraajanagara-571313, has been inspected on 11-03-2026 Wednesday, certify that the accommodation provided for each of the several rooms is sufficient for the maximum number of inmates strength there in and that the building is properly ventilated and lighted, that it is maintained substantially repaired, that it is neat and clean that the latrine arrangements are adequate and satisfactory, that the supply of drinking water is wholesome and good and that in all other aspects the sanitation is satisfactory.

Issued on: 11-03-2026

Valid on: 10-03-2027


Senior Health Inspector
City Municipal Council, Chamaraajanagar
CMC, Chamaraajanagara


Environmental Engineer
City Municipal Council, Chamaraajanagar
CMC, Chamaraajanagara

Office of the Executive Engineer
RDW&S Department
Chamarajanagara Division
Chamarajanagara



☎ :Office And EE : 08226 -226054
E-mail : eerdwsd.chn2014@gmail.com

No.EE/ RDW&SD/Ch-nagar/Lab/ 2025-26

/1020A

Date: 9/03/2026

To,

The Principal
JSS Public School
B. Rachaiah Double Road
Chamarajanagara.

Respected Sir,

Sub: Submitting the RO Filter Water Analysis Report .

Ref: ಜೆಎಸ್‌ಎಸ್ ಪಿಎಸ್/ನಿಎನ್ ಆರ್/429/2025-26 Dated: 03-03-2026

With Respect to the above subject and reference, we have received 02 No's of Water Samples from JSS Public School, Chamarajanagara. On 03-03-2026. We are here with the Water analysis report (1No's RO Treated water). Analyzed as per IS (Indian standard) 10500:2012 for 15 parameters in our laboratory and please find the attached reports with the letter.

Enclosed:

1. Test Reports of water samples.
2. Tax Invoice.


Executive Engineer
RDW&S Department
Chamarajanagara Division
Chamarajanagara



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK

District Drinking Water Quality Testing Laboratory

PRED Premises, Court Road, Chamarajanagara.

Chamarajanagara- 571313

e-mail: rdwdsd.wqmosp.chnagar@gmail.com

TEST REPORT

| Address of the sampling location: Taluk: Chamarajanagara Location : JSS Public School, B. Rachaya double road, Chamarajanagara town. 571313 | | | | Report date: 05-03-2026 | |
|--|--|-----------|--|---|---|
| | | | | Report Number: CHN26MAR0006 | |
| | | | | Reference: Sample Receipt Form | |
| | | | | Sample receipt date: 03-03-2026 | |
| | | | | Sample Code: CHN26MAR0006 | |
| | | | | Date of Sample collection: 03-03-2026 | |
| | | | | Analysis start date: 04-03-2026 | |
| | | | | Analysis completion date: 05-03-2026 | |
| | | | | Sample collection protocol: RDWSD/WQMSP/SOP/23 | |
| Sample Particulars: Filtered Water | | | | Sample quantity: 1Liter | |
| Sl.No | Test | Results | Acceptable Limit IS 10500 : 2012 RA:2018 | Permissible Limit IS 10500 : 2012 RA:2018 | Protocol |
| Description: | | | | | |
| 1. | pH Value @25.0 °C | 8.01 | 6.5 – 8.5 | No relaxation | IS 3025 (Part-11) : 2022 |
| 2. | Specific Conductance, $\mu\text{S}/\text{cm}$ @25.0 °C | 190 | — | — | IS 3025 (Part-14) : 2013 |
| 3. | Odour | Agreeable | Agreeable | Agreeable | IS 3025 (Part-5 & 6):2018 |
| 4. | Colour, Hazen Units | 1 | 5 | 15 | IS 3025 (Part-4) : 2021 |
| 5. | Turbidity, NTU | <0.5 | 1 | 5 | IS 3025 (Part-10) :1984 |
| 6. | Total Dissolved Solids @ 180 °C, mg/l | 124 | 500 | 2000 | IS 3025 (Part-16) : 1984 |
| 7. | Alkalinity as CaCO_3 , mg/l | 31.52 | 200 | 600 | IS 3025 (Part-23) : 1986 |
| 8. | Total Hardness as CaCO_3 , mg/l | 47.12 | 200 | 600 | IS 3025 (Part-21) : 2009 |
| 9. | Calcium as Ca, mg/l | 10.29 | 75 | 200 | IS 3025 (Part-40) : 1991 |
| 10. | Magnesium as Mg, mg/l | 5.20 | 30 | 100 | IS 3025 (Part-46) : 1994 |
| 11. | Chloride as Cl, mg/l | 25.44 | 250 | 1000 | IS 3025 (Part-32) : 1988 |
| 12. | Sulphate as SO_4 , mg/l | 6.60 | 200 | 400 | IS 3025 (Part-24) : 2022 |
| 13. | Fluoride as F, mg/l | <0.01 | 1 | 1.5 | APHA 23 rd Edition, 4500-F:D |
| 14. | Nitrate as NO_3 , mg/l | 5.29 | 45 | No relaxation | APHA 23 rd Edition, 4500-NO3-B |
| 15. | Iron as Fe, mg/l | <0.01 | 1 | No relaxation | IS 3025 (Part-53) : 2003 |
| Remarks: The above tested Physical & Chemical parameters are Conforms to the Acceptable Limit as per IS 10500:2012 Drinking Water Specification for the given sample only. | | | | | |
| Analysed by:  RAVIKUMARA C M (Junior Analyst) | | | Authorized Signatory :  KOWSHIK DEV M S (Technical Manager) RDWSD/WQMSP/TeR/01 | | |

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

Office of the Executive Engineer
RDW&S Department
Chamarajanagara Division
Chamarajanagara



☎ :Office And EE : 08226 -226054
E-mail : eerdwsd.chn2014@gmail.com

No.EE/ RDW&SD/Ch-nagar/Lab/ 2025-26 /1020

Date: 9/03/2026

To,

The Principal
JSS Public School
B. Rachaiah Double Road
Chamarajanagara.

Respected Sir,

Sub: Submitting the Borewel Water Analysis Report .

Ref : ಜೆಎಸ್‌ಎಸ್ ಪಿಎಸ್/ಸಿಎಸ್ ಆರ್/429/2025-26 Dated: 03-03-2026

With Respect to the above subject and reference, we have received 01 No's of Water Samples from JSS Public School, Chamarajanagara. On 03-03-2026. We are here with the Water analysis report (1No's Raw Water). Analyzed as per IS (Indian standard) 10500:2012 for 15 parameters in our laboratory and please find the attached reports with the letter.

Enclosed:

1. Test Reports of water samples.
2. Tax Invoice.


Executive Engineer
RDW&S Department
Chamarajanagara Division
Chamarajanagara



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK

District Drinking Water Quality Testing Laboratory

PRED Premises, Court Road, Chamarajanagara.

Chamarajanagara- 571313

e-mail: rdwdsd.wqmssp.chnagar@gmail.com

TEST REPORT

| Address of the sampling location: Taluk: Chamarajanagara Location : JSS Public School, B. Rachaya double road, Chamarajanagara town. 571313 | | | | Report date: 05-03-2026 | |
|---|--|-----------|---|---|---|
| | | | | Report Number: CHN26MAR0005 | |
| | | | | Reference: Sample Receipt Form | |
| | | | | Sample receipt date: 03-03-2026 | |
| | | | | Sample Code: CHN26MAR0005 | |
| | | | | Date of Sample collection: 03-03-2026 | |
| | | | | Analysis start date: 04-03-2026 | |
| Sample Particulars: Borewell Water | | | | Analysis completion date: 05-03-2026 | |
| | | | | Sample collection protocol: RDWSD/WQMSP/SOP/23 | |
| | | | | Sample quantity: 1Liter | |
| Sl.No | Test | Results | Acceptable Limit IS 10500 : 2012 RA:2018 | Permissible Limit IS 10500 : 2012 RA:2018 | Protocol |
| Description: | | | | | |
| 1. | pH Value @25.0 °C | 7.38 | 6.5 – 8.5 | No relaxation | IS 3025 (Part-11) : 2022 |
| 2. | Specific Conductance, $\mu\text{S}/\text{cm}$ @25.0 °C | 1590 | — | — | IS 3025 (Part-14) : 2013 |
| 3. | Odour | Agreeable | Agreeable | Agreeable | IS 3025 (Part-5 & 6):2018 |
| 4. | Colour, Hazen Units | 1 | 5 | 15 | IS 3025 (Part-4) : 2021 |
| 5. | Turbidity, NTU | <0.5 | 1 | 5 | IS 3025 (Part-10) :1984 |
| 6. | Total Dissolved Solids @ 180 °C, mg/l | 1034 | 500 | 2000 | IS 3025 (Part-16) : 1984 |
| 7. | Alkalinity as CaCO_3 , mg/l | 433.4 | 200 | 600 | IS 3025 (Part-23) : 1986 |
| 8. | Total Hardness as CaCO_3 , mg/l | 565.47 | 200 | 600 | IS 3025 (Part-21) : 2009 |
| 9. | Calcium as Ca, mg/l | 133.77 | 75 | 200 | IS 3025 (Part-40) : 1991 |
| 10. | Magnesium as Mg, mg/l | 56.16 | 30 | 100 | IS 3025 (Part-46) : 1994 |
| 11. | Chloride as Cl, mg/l | 176.12 | 250 | 1000 | IS 3025 (Part-32) : 1988 |
| 12. | Sulphate as SO_4 , mg/l | 38.70 | 200 | 400 | IS 3025 (Part-24) : 2022 |
| 13. | Fluoride as F, mg/l | 0.54 | 1 | 1.5 | APHA 23 rd Edition, 4500-F:D |
| 14. | Nitrate as NO_3 , mg/l | 26.76 | 45 | No relaxation | APHA 23 rd Edition, 4500-NO3-B |
| 15. | Iron as Fe, mg/l | <0.01 | 1 | No relaxation | IS 3025 (Part-53) : 2003 |
| Remarks: The above tested Physical & Chemical parameters are Conforms to the Permissible Limit as per IS 10500:2012 Drinking Water Specification for the given sample only. | | | | | |
| Analysed by: RAVIKUMARA C M (Junior Analyst) | | | Authorized Signatory : KOWSHIK DEV M S (Technical Manager) | | |

RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.